



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Jun-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 22-Jun-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 23.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	22-Jun-19	0:00:00	22-Jun-19	22:30:00	22:30:00	34.00	0.756	
5	22-Jun-19	18:00:00	22-Jun-19	24:00:00	6:00:00	33.00	0.197	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:34:00	0	0.040	Today(i.e. 23.06.2019), no SSP-RBPH M/c is scheduled. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0	0.000	
3	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0	0.000	
4	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0	0.000	
5	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0	0.000	
6	22-Jun-19	0:00:00	22-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.953	0.040	0.993
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.683	0.040	18.723
PREVIOUS DAY ACTUAL RUNNING HOURS	28:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres * 119.76 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12148 Cusec
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5935 Cusec
- GOG WATER REQUIREMENT(Next Day) in Cusec 29.72 MCM
- 14.52 MCM

HR	GODBOLE
3954	1075

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
1042	0	6	5935	0	389



जल नियंत्रण - जल संयंत्र

AEE (EMC)
NCA, INDORE

Archita Karungo
J.E. (Elect.)
EMC, NCA.
23.6.19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor and Dhule-2 lines are in service.

2. SCO Mode Running Detail:

- Unit No.3: 20:30 hrs on 22.06.2019 to 08:30 hrs on 23.06.2019.
- Unit No.4: 20:40 hrs on 22.06.2019 to 08:35 hrs on 23.06.2019