



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Jun-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 23-Jun-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0.00	0.000	Today (i.e. 24.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0.00	0.000	
5	23-Jun-19	0:00:00	23-Jun-19	24:00:00	24:00:00	35.00	0.787	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0	0.000	Today (i.e. 24.06.2019), no SSP-RBPH M/c is scheduled. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0	0.000	
3	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0	0.000	
4	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0	0.000	
5	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0	0.000	
6	23-Jun-19	0:00:00	23-Jun-19	0:00:00	0:00:00	0	0.000	

CHPH (5 X 50MW)

RBPH (6X200 MW)

SSP (CHPH+RBPH)

GROSS GENERATION IN (MUs)	0.787	0.000	0.787
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	19.470	0.040	19.510
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 24-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.72 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3072 Cusec
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5015 Cusec
- GOG WATER REQUIREMENT (Next Day) in Cusec 12.27 MCM

HR	GODBOLE
3954	1042

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
1122	0	3911	5015	0	390



AEE (EMC)
NCA, INDORE

for Aochita Kowungee
J.E. (Elect)
EMC, NCA
24.6.19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE (E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.3: 18:30 hrs on 23.06.2019 to 07:05 hrs on 24.06.2019.