

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 25.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	24-Jun-19	18:00:00	24-Jun-19	24:00:00	6:00:00	35.00	0.204	
5	24-Jun-19	0:00:00	24-Jun-19	20:30:00	20:30:00	34.00	0.678	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0	0.012	Today(i.e. 25.06.2019), no SSP-RBPH M/c is scheduled. Wet Test of Unit No.2 to carry out today on 25.06.2019. Wet Test of Unit No.1 held yesterday on 24.06.2019. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0	0.000	
3	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0	0.000	
4	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0	0.000	
5	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0	0.000	
6	24-Jun-19	0:00:00	24-Jun-19	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)		RBPH (6X200 MW)		SSP(CHPH+RBPH)	
GROSS GENERATION IN(MUs)					0.882		0.012		0.894	
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)					20.352		0.052		20.404	
PREVIOUS DAY ACTUAL RUNNING HOURS					26:30:00		0:00:00			
TODAY'S DC (Schedule) Planned (in Hours)					24:00:00		0:00:00			
DAY AHEAD (TOMMORROW) DC (in Hours)					24:00:00		0:00:00			

SSP hydrological data : at 08:00 Hrs on 25-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.72 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6004 Cusec 14.69 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5597 Cusec 13.69 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3911	1122

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
1090	0	3649	5581	16	389



(Signature)

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail: Nil.