



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Jun-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 25-Jun-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 26.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	25-Jun-19	0:00:00	25-Jun-19	24:00:00	24:00:00	35.00	0.817	
5	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 26.06.2019), no SSP-RBPH M/c is scheduled. Wet Test of Unit No.3 to carry out today on 26.06.2019. Wet Test of Unit No.2 carried yesterday on 25.06.2019. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	25-Jun-19	09:35 10:25 11:25 12:24 13:23 14:24	25-Jun-19	09:37 10:36 11:35 12:34 13:34 14:34	0:54:00	121	0.056	
3	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0	0.000	
4	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0	0.000	
5	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0	0.000	
6	25-Jun-19	0:00:00	25-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.817	0.056	0.873
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	21.169	0.108	21.277
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:54:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.70 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4662 Cusec 11.41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5447 Cusec 13.33 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3649	1090

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
1109	0	3155	5181	266	389



for *[Signature]* 26/06/19
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 01:35 hrs on 26.06.2019 to 06:20 hrs on 26.06.2019

Unit No.1: 03:05 hrs on 26.06.2019 to 06:25 hrs on 26.06.2019