



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 27.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	26-Jun-19	0:00:00	26-Jun-19	24:00:00	24:00:00	36.00	0.808	
5	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0.00	0.000	

**(RBPB 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 27.06.2019), no SSP-RBPB M/c is scheduled. Wet Test of Unit No.4 to carry out today on 27.06.2019. Wet Test of Unit No.3 to carry out today on 26.06.2019. Wet Test of Unit No.2 carried yesterday on 25.06.2019. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	121	0.000	
3	26-Jun-19	10:04 11:05 12:05	26-Jun-19	10:14 11:15 12:15	0:54:00	120	0.060	
4	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0	0.000	
5	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0	0.000	
6	26-Jun-19	0:00:00	26-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUS)	0.808	0.060	0.868
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	21.977	0.168	22.145
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:54:00	
TODAY'S DC (Schedule) Planned (in Hours)	19:30:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 27-Jun-19

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 119.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3567 Cusec 9 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4352 Cusec 11 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3155	1109

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
1114	0	3155	4114	238	389



जल संचय - जल संयोजक

for  
27/06/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 00:45 hrs on 27.06.2019 to 05:45 hrs on 27.06.2019

AEE (EMC)  
NCA, INDORE