



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jun-19	6:30:00	27-Jun-19	17:45:00	11:15:00	35.00	0.372	Today(i.e. 28.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	27-Jun-19	0:00:00	27-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	27-Jun-19	17:40:00	27-Jun-19	24:00:00	6:20:00	32.00	0.203	
4	27-Jun-19	0:00:00	27-Jun-19	2:00:00	2:00:00	34.00	0.066	
5	27-Jun-19	0:00:00	27-Jun-19	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jun-19	0:00:00	27-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 28.06.2019), no SSP-RBPH M/c is scheduled. Wet Test of Unit No.5 to carry out today on 28.06.2019. SCO Test of Unit No.6 to carry out today on 28.06.2019. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	27-Jun-19	0:00:00	27-Jun-19	0:00:00	0:00:00	121	0.000	
3	27-Jun-19	0:00:00	27-Jun-19	0:00:00	0:00:00	0	0.000	
4	27-Jun-19	09:33 10:19 11:19 12:19 13:33 14:33	27-Jun-19	09:35 10:29 11:29 12:29 13:44 14:44	0:54:00	120	0.060	
5	27-Jun-19	0:00:00	27-Jun-19	0:00:00	0:00:00	0	0.000	
6	27-Jun-19	0:00:00	27-Jun-19	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.641	0.060	0.701
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		22.618	0.228	22.846
PREVIOUS DAY ACTUAL RUNNING HOURS		19:35:00	0:54:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 28-Jun-19

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 119.65 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3779 Cusec 9 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5138 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3136	1114

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
1010	0	3136	4944	194	389



*for check*  
28.6.19  
JG, 5 MCM, NCA

AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail: NIL