



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Jun-19	11:10:00	28-Jun-19	20:40:00	9:30:00	32.00	0.301	Today(i.e. 29.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	28-Jun-19	00:00 20:35	28-Jun-19	11:15 24:00	14:40:00	34.00	0.484	
4	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0.00	0.000	
5	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 29.06.2019), no SSP-RBPH M/c is scheduled. Wet Test of Unit No.6 to carry out today on 29.06.2019. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0	0.000	
3	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0	0.000	
4	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0	0.000	
5	28-Jun-19	9:37 10:04 11:04	28-Jun-19	9:39 10:14 11:15	0:54:00	120	0.060	
6	28-Jun-19	0:00:00	28-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.785	0.060	0.845
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	23.403	0.288	23.691
PREVIOUS DAY ACTUAL RUNNING HOURS	24:10:00	0:54:00	
TODAY'S DC (Schedule) Planned (in Hours)	10:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 29-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.62 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3849 Cusec 9 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5200 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3136	1010

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
1024	0	3136	4929	271	388



जल संचयन - जल संयोजन

for
29/06/19

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.3: 18:35 hrs on 28.06.2019 to 09:30 hrs on 29.06.2019

Unit No.2: 18:45 hrs on 28.06.2019 to 09:25 hrs on 29.06.2019

AEE (EMC)
NCA, INDORE