

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 30.06.2019), 0 CHPH M/c is running at 10:00 hrs.
2	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	29-Jun-19	0:00:00	29-Jun-19	10:00:00	10:00:00	33.00	0.322	
4	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0.00	0.000	
5	29-Jun-19	17:30:00	29-Jun-19	24:00:00	6:30:00	34.00	0.209	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 30.06.2019), no SSP-RBPH M/c is scheduled.
2	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0	0.000	
3	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0	0.000	
4	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0	0.000	
5	29-Jun-19	0:00:00	29-Jun-19	0:00:00	0:00:00	0	0.000	
6	29-Jun-19	10:20 10:48 12:10 13:18 14:03 14:49	29-Jun-19	10:22 10:58 12:20 13:28 14:13 14:59	0:52:00	120	0.054	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.531	0.054	0.585
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	23.934	0.342	24.276
PREVIOUS DAY ACTUAL RUNNING HOURS	16:30:00	0:52:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6074 Cusec 15 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2169 Cusec 5 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3126	1024

• AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
983	0	3126	1921	248	388



(Signature)
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 21:15 hrs on 29.06.2019 to 10:10 hrs on 30.06.2019

Unit No.2: 21:20 hrs on 29.06.2019 to 09:20 hrs on 30.06.2019