



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Jun-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-Jun-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 04.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	3-Jun-19	16:15:00	3-Jun-19	24:00:00	7:45:00	34.00	0.260	
3	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0.00	0.000	
5	3-Jun-19	0:00:00	3-Jun-19	11:00:00	11:00:00	34.00	0.362	

(RRPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 04.06.2019), no SSP-RRPH M/c is scheduled. Unit No.1 is under outage from 03.05.2019 at 9:00 Hrs. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs. Unit No.3 is under outage from 21.05.2019 at 9:30 Hrs.
2	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0	0.000	
3	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0	0.000	
4	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0	0.000	
5	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0	0.000	
6	3-Jun-19	0:00:00	3-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RRPH (6X200 MW)	SSP(CHPH+RRPH)
GROSS GENERATION IN(MUs)	0.622	0.000	0.622
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	2.430	0.000	2.430
PREVIOUS DAY ACTUAL RUNNING HOURS	18:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.26 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5862 Cusec 14 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3232 Cusec 8 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3198	1523

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RRPH	Ev. Loss
1521	0	2975	3232	0	398

for Archita Kauringe
J.B. (Block 2)
EMC, NCA
4.6.19

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMab. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasar, Dhule-2, Dhule-1 and Raj-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.4: 18:50 hrs on 03.06.2019 to 06:30 hrs on 04.06.2019

Unit No.5: 19:00 hrs on 03.06.2019 to 07:05 hrs on 04.06.2019