



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Mar-18	0:00:00 +	2-Mar-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).  SSP-CHPH Unit no. 2 is under AOH from dt. 27.02.2018
2	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0.00	0.000	
3	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0.00	0.000	
4	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0.00	0.000	
5	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0.00	0.000	

**(RBPB 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0	0.000	SSP-RBPB units will not be scheduled as Dam Level is below MDDL(110.64m).  SSP-RBPB Unit no. 2 is under AOH from dt. 14.02.2018
2	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0	0.000	
3	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0	0.000	
4	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0	0.000	
5	2-Mar-18	0:00:00 +	2-Mar-18	0:00:00	0:00:00	0	0.000	
6	2-Mar-18	0:00:00	2-Mar-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUS)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Mar-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 108.30 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 0 Cusec 0.000 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10412 Cusec 25 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
9756	613

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB
613	0	9699	0	0



for *Tarun/Alw*  
03/03/18

AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE : I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

II) SSP-RBPB SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.

III) IBPT operated for maintaining environmental flow into the downstream.