



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0,00	0,000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m). SSP-CHPH Unit no. 1 is under AOH from dt. 20.03.2018
2	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0,00	0,000	
3	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0,00	0,000	
4	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0,00	0,000	
5	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0,00	0,000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0	0,000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m). SSP-RBPH Unit no. 3 is under AOH from dt. 09.03.2018
2	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0	0,000	
3	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0	0,000	
4	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0	0,000	
5	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0	0,000	
6	29-Mar-18	0:00:00	29-Mar-18	0:00:00	0:00:00	0	0,000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Mar-18

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 105.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2720 Cusec 7 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3599 Cusec 9 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec.

HR	GODBOLE
2858	637

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
639	0	2858	0	0	3599



नर्मदा नियंत्रण प्राधिकरण

for
20/03/18

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP, Member(Power),NVDA,Bhopal
- GoMah, CE,WRD, Mumbai
- GoG, CE(E&M),SSNNL,Vadodra

NOTE :I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.
III) IBPT operated for maintaining environmental flow into the downstream.

AEE (EMC)
NCA, INDORE