

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Mar-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 09-Mar-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Mar-19	11:00:00	9-Mar-19	24:00:00	13:00:00	25.00	0.320	Today(i.e. 10.03.2019), 2 CHPH M/c are running at 10:00 hrs. Unit No. 5 is under AOH since 05.03.2019.
2	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0.00	0.000	
3	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0.00	0.000	
4	9-Mar-19	0:00:00	9-Mar-19	24:00:00	24:00:00	27.00	0.638	
5	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0	0.000	Today(i.e. 10.03.2019), no SSP-RBPH M/c is scheduled.
2	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0	0.000	
3	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0	0.000	
4	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0	0.000	
5	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0	0.000	
6	9-Mar-19	0:00:00	9-Mar-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.958	0.000	0.958
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	10.251	0.000	10.251
PREVIOUS DAY ACTUAL RUNNING HOURS	37:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Mar-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.07 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7946 Cusec 19 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6971 Cusec 17 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
6504	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
608	0	6598	6971	0	375



For Archita Kawange
10-3-19

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Raj-1 and Dhule-1 lines are in service.

2. SSP SCO Running Details:

Unit No.2: 02:05 hrs on 10.03.19 to 08:45 hrs on 10.03.19.

Unit No.6: 02:15 hrs on 10.03.19 to 07:45 hrs on 10.03.19.