



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Mar-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 10-Mar-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 11.03.2019), 2 CHPH M/c are running at 10:00 hrs. Unit No. 5 is under AOH since 05.03.2019.
2	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0.00	0.000	
3	10-Mar-19	10:00:00	10-Mar-19	24:00:00	14:00:00	28.00	0.385	
4	10-Mar-19	0:00:00	10-Mar-19	24:00:00	24:00:00	28.00	0.616	
5	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0	0.000	Today(i.e. 11.03.2019), no SSP-RBPH M/c is scheduled.
2	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0	0.000	
3	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0	0.000	
4	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0	0.000	
5	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0	0.000	
6	10-Mar-19	0:00:00	10-Mar-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.001	0.000	1.001
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	11.252	0.000	11.252
PREVIOUS DAY ACTUAL RUNNING HOURS	38:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Mar-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.04 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5792 Cusec 14 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7163 Cusec 18 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6598	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
606	0	6598	7163	0	375



*[Signature]*  
AEE (EMC)  
NCA, INDORE  
11/3/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kosor,Raj-1,Raj-2,Dhule-1 and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.2: 14:40 hrs on 10.03.19 to 06:30 hrs on 11.03.19.

Unit No.6: 02:30 hrs on 11.03.19 to 07:25 hrs on 11.03.19.

Unit No.1: 02:35 hrs on 11.03.19 to 06:35 hrs on 11.03.19.