

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Mar-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 12-Mar-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Mar-19	0:00:00	12-Mar-19	24:00:00	24:00:00	27.00	0.626	Today(i.e. 13.03.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 5 is under AOH since 05.03.2019.
2	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0.00	0.000	
3	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0.00	0.000	
4	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0.00	0.000	
5	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0	0.000	Today(i.e. 13.03.2019), no SSP-RBPH M/c is scheduled. Unit No. 5 is under AOH from 12.03.2019 at 9:00 Hrs..
2	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0	0.000	
3	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0	0.000	
4	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0	0.000	
5	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0	0.000	
6	12-Mar-19	0:00:00	12-Mar-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.626	0.000	0.626
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	12.807	0.000	12.807
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Mar-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.03 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4909 Cusec 12 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4533 Cusec 11 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
5664	625

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
612	0	5077	4533	0	374



*(Signature)*  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Raj-1,Raj-2, and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.2: 20:05 hrs on 12.03.19 to 06:25 hrs on 13.03.19.

Unit No.6: 20:10 hrs on 12.03.19 to 06:30 hrs on 13.03.19.