



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Mar-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 19-Mar-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 20.03.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 5 is under AOH since 09.03.2019.
2	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0.00	0.000	
3	19-Mar-19	17:30:00	19-Mar-19	24:00:00	6:30:00	26.00	0.167	
4	19-Mar-19	0:00:00	19-Mar-19	21:30:00	21:30:00	27.00	0.565	
5	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0	0.000	Today(i.e. 20.03.2019), no SSP-RBPH M/c is scheduled. Unit No. 5 is under AOH from 12.03.2019 at 9:00 Hrs..
2	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0	0.000	
3	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0	0.000	
4	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0	0.000	
5	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0	0.000	
6	19-Mar-19	0:00:00	19-Mar-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.732	0.000	0.732
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	17.765	0.000	17.765
PREVIOUS DAY ACTUAL RUNNING HOURS	28:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Mar-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.50 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14938 Cusec 37 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5206 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4226	612

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
618	0	4227	5206	0	380



*[Signature]*  
20/3  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Raj-1, Raj-2, Dhule-1 and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.3: 20:50 hrs on 19.03.19 to 07:45 hrs on 20.03.19.

Unit No.4: 21:00 hrs on 19.03.19 to 07:50 hrs on 20.03.19.