



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Mar-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Mar-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Mar-19	0:00:00	5-Mar-19	12:00:00	12:00:00	25.00	0.302	Today(i.e. 06.03.2019), 1 CHPH M/c is running at 10:00 hrs.
2	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0.00	0.000	
3	5-Mar-19	0:00:00	5-Mar-19	24:00:00	24:00:00	27.00	0.637	
4	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0.00	0.000	
5	5-Mar-19	20:00:00	5-Mar-19	24:00:00	4:00:00	27.00	0.106	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0	0.000	Today(i.e. 06.03.2019), no SSP-RBPH M/c is scheduled. SSP-RBPH Unit no.4 under AOH work from 15.02.2019.
2	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0	0.000	
3	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0	0.000	
4	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0	0.000	
5	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0	0.000	
6	5-Mar-19	0:00:00	5-Mar-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.045	0.000	1.045
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	6.346	0.000	6.346
PREVIOUS DAY ACTUAL RUNNING HOURS	40:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	31:30:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Mar-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 16174 Cusec 40 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7635 Cusec 19 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7584	619

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
614	0	7588	7635	0	371



AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC.REA.
1. 400 kV SSP Asoj, Kasor/Raj.-2, and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.5: 20:10 hrs on 05.03.19 to 05:40 hrs on 06.03.19.

Unit No.2: 20:15 hrs on 05.03.19 to 05:25 hrs on 06.03.19.

Handwritten signature and date: 06/03