



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Mar-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 08-Mar-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 09.03.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 5 is under AOH since 05.03.3019.
2	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0.00	0.000	
3	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0.00	0.000	
4	8-Mar-19	0:00:00	8-Mar-19	24:00:00	24:00:00	28.00	0.639	
5	8-Mar-19	11:30:00	8-Mar-19	24:00:00	12:30:00	26.00	0.313	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0	0.000	Today(i.e. 09.03.2019), no SSP-RBPH M/c is scheduled.
2	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0	0.000	
3	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0	0.000	
4	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0	0.000	
5	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0	0.000	
6	8-Mar-19	0:00:00	8-Mar-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.952	0.000	0.952
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.293	0.000	9.293
PREVIOUS DAY ACTUAL RUNNING HOURS	36:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Mar-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.06 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7240 Cusec 18 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6866 Cusec 17 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6504	611

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
608	0	6504	6866	0	375



For Archita Kamargo
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Raj-1 and Dhule-1 lines are in service.

2. SSP SCO Running Details:

Unit No.2: 21:30 hrs on 08.03.19 to 06:50 hrs on 09.03.19.

Unit No.6: 21:25 hrs on 08.03.19 to 06:55 hrs on 09.03.19.