



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Mar-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 12-Mar-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Mar-20	0:00:00	12-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 13.03.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 2 is under L/C from 01.03.2020. SSP CHPH Unit No. 1 is under L/C from 08.03.2020.
2	12-Mar-20	0:00:00	12-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	12-Mar-20	0:00:00	12-Mar-20	24:00:00	24:00:00	43.00	1.006	
4	12-Mar-20	0:00:00	12-Mar-20	24:00:00	24:00:00	42.00	1.000	
5	12-Mar-20	0:00:00	12-Mar-20	24:00:00	24:00:00	42.00	0.982	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Mar-20	6:15 14:15	12-Mar-20	11:30 18:45	9:45:00	178	1.704	Today(i.e. 13.03.2020), 2 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
2	12-Mar-20	6:00 14:30	12-Mar-20	11:45 19:00	10:15:00	178	1.800	
3	12-Mar-20	5:45 14:45	12-Mar-20	12:00 19:15	10:45:00	179	1.878	
4	12-Mar-20	6:30:00	12-Mar-20	19:30:00	13:00:00	178	2.280	
5	12-Mar-20	0:00:00	12-Mar-20	0:00:00	0:00:00	0	0.000	
6	12-Mar-20	5:30 15:00	12-Mar-20	12:15 19:45	11:30:00	178	2.034	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.988	9.696	12.684
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	37.174	51.834	89.008
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	55:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	33:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	34:45:00	

SSP hydrological data : at 08:00 Hrs on 13-Mar-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 123.11 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18358 Cusec 45 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 31189 Cusec 76 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15507	512

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
595	0	15560	16070	15119	498



[Signature]
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.6: 20:30 hrs on 12.03.2020 to 05:10 hrs on 13.03.2020.

Unit No.2: 01:55 hrs on 13.03.2020 to 05:15 hrs on 13.03.2020.

Unit No.3: 2:05 hrs on 13.03.2020 to 05:20 hrs on 13.03.2020.