



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Mar-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 15-Mar-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Mar-20	0:00:00	15-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 16.03.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 2 is under L/C from 01.03.2020. SSP CHPH Unit No. 1 is under L/C from 08.03.2020.
2	15-Mar-20	0:00:00	15-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	15-Mar-20	0:00:00	15-Mar-20	24:00:00	24:00:00	41.00	0.962	
4	15-Mar-20	0:00:00	15-Mar-20	24:00:00	24:00:00	42.00	0.995	
5	15-Mar-20	0:00:00	15-Mar-20	24:00:00	24:00:00	42.00	0.974	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Mar-20	07:00 16:45	15-Mar-20	10:15 19:30	6:00:00	176	1.048	Today(i.e. 16.03.2020), 2 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
2	15-Mar-20	06:45 16:15	15-Mar-20	11:45 19:00	7:45:00	176	1.354	
3	15-Mar-20	06:30 16:30	15-Mar-20	12:00 19:15	8:15:00	176	1.438	
4	15-Mar-20	6:00:00	15-Mar-20	9:45:00	3:45:00	174	0.658	
5	15-Mar-20	0:00:00	15-Mar-20	0:00:00	0:00:00	0	0.000	
6	15-Mar-20	6:15:00	15-Mar-20	10:00:00	3:45:00	174	0.652	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		2.931	5.150	8.081
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		45.975	68.910	114.885
PREVIOUS DAY ACTUAL RUNNING HOURS		72:00:00	29:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	29:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	30:30:00	

SSP hydrological data : at 08:00 Hrs on 16-Mar-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.07 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 25312 Cusec 62 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24076 Cusec 59 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15109	598

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
572	0	15556	16068	8008	495



जल बचत - जल संयत

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.6: 19:40 hrs on 15.03.2020 to 05:25 hrs on 16.03.2020.

Unit No.3: 19:45 hrs on 15.03.2020 to 05:20 hrs on 16.03.2020.

Unit No.2: 20:05 hrs on 15.03.2020 to 05:15 hrs on 16.03.2020.

Taiseef Ah
JE (EMC)
16/3/2020

AEE (EMC)
NCA, INDORE