



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Mar-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Mar-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|---|
| 1 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 24:00:00 | 24:00:00 | 13.00 | 0.303 | Today(i.e. 02.03.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 11:33:00 | 11:33:00 | 13.00 | 0.138 | |
| 3 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 24:00:00 | 24:00:00 | 43.00 | 0.991 | |
| 4 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 24:00:00 | 24:00:00 | 44.00 | 1.035 | |
| 5 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 24:00:00 | 24:00:00 | 42.00 | 0.988 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|---------|----------|---------|-------------|----------------|-------------------|---|
| 1 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 02.03.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. SSP-RBPH M/cs are scheduled for operation but not synchronised by RBPH C/R even after issuing code by WRLCD. RBPH Unit No. 4 is under AOH from 11.02.2020 to 02.03.2020 |
| 2 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 1-Mar-20 | 0:00:00 | 1-Mar-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 3.455 | 0.000 | 3.455 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 3.455 | 0.000 | 3.455 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 107:33:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 27:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 27:00:00 | |

SSP hydrological data : at 08:00 Hrs on 2-Mar-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.13 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 23397 Cusec 57 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17696 Cusec 43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 18451 | 648 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 616 | 0 | 17736 | 17696 | 0 | 518 |



जल संयंत्र - जल संचय

[Signature]
2/2/2020
AEE (BMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Dhule-I, Dhule-II, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 19:10 hrs on 01.03.2020 to 05:50 hrs on 02.03.2020.

Unit No.6: 19:15 hrs on 01.03.2020 to 05:55 hrs on 02.03.2020.

Unit No.2: 20:15 hrs on 01.03.2020 to 05:45 hrs on 02.03.2020.