

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-Mar-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 27-Mar-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	27-Mar-20	0:00:00	27-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 28.03.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	27-Mar-20	0:00:00	27-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	27-Mar-20	0:00:17:00	27-Mar-20	8:00:24:00	15:00:00	39.00	0.587	
4	27-Mar-20	0:00:00	27-Mar-20	24:00:00	24:00:00	41.00	0.947	
5	27-Mar-20	0:00:00	27-Mar-20	24:00:00	24:00:00	40.00	0.922	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	27-Mar-20	6:15:00	27-Mar-20	8:45:00	2:30:00	180	0.448	Today(i.e. 28.03.2020), 1 SSP-RBPH M/cs are running at 10:00 hrs.
2	27-Mar-20	5:45:00	27-Mar-20	9:00:00	3:15:00	182	0.576	
3	27-Mar-20	0:00:00	27-Mar-20	0:00:00	0:00:00	0	0.000	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	27-Mar-20	0:00:00	27-Mar-20	0:00:00	0:00:00	0	0.000	
5	27-Mar-20	0:00:00	27-Mar-20	0:00:00	0:00:00	0	0.000	
6	27-Mar-20	6:00:16:00	27-Mar-20	11:45:19:00	8:45:00	185	1.584	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		2.456	2.608	5.064
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		79.732	126.364	206.096
PREVIOUS DAY ACTUAL RUNNING HOURS		63:00:00	14:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	14:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	13:30:00	

SSP hydrological data : at 08:00 Hrs on 28-Mar-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12323 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16286 Cusec 40 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14204	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	12948	12254	4032	480



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadodra

AEE (EMC)
NCA, INDORE

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.2:18:30 hrs on 27.03.2020 to 5:00 hrs on 28.03.2020.

Unit No.1: 18:40 hrs on 27.03.2020 to 05:05 hrs on 28.03.2020