

**DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 29-Mar-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 28-Mar-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Mar-20	0:00:00	28-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 29.03.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	28-Mar-20	0:00:00	28-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	28-Mar-20	0:00:00	28-Mar-20	24:00:00	24:00:00	39.00	0.923	
4	28-Mar-20	0:00:00	28-Mar-20	24:00:00	24:00:00	40.00	0.943	
5	28-Mar-20	0:00:12:00	28-Mar-20	0:30:23:00	11:30:00	39.00	0.436	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Mar-20	5:45:00	28-Mar-20	8:45:00	3:00:00	185	0.554	Today(i.e. 29.03.2020), 1 SSP-RBPH M/cs are running at 10:00 hrs.
2	28-Mar-20	6:00:00	28-Mar-20	9:00:00	3:00:00	185	0.554	
3	28-Mar-20	0:00:00	28-Mar-20	0:00:00	0:00:00	0	0.000	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	28-Mar-20	0:00:00	28-Mar-20	0:00:00	0:00:00	0	0.000	
5	28-Mar-20	0:00:00	28-Mar-20	0:00:00	0:00:00	0	0.000	
6	28-Mar-20	6:15:16:00	28-Mar-20	11:45:19:00	8:30:00	185	1.566	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		2.302	2.674	4.976
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		82.034	129.038	211.072
PREVIOUS DAY ACTUAL RUNNING HOURS		59:30:00	14:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	14:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	14:45:00	

SSP hydrological data : at 08:00 Hrs on 29-Mar-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 122.20 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8564 Cusec 21 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16973 Cusec 42 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12947	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	12381	12946	4027	478



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.21:10 hrs on 28.03.2020 to 5:00 hrs on 29.03.2020.

Unit No.1: 21:00 hrs on 28.03.2020 to 05:00 hrs on 29.03.2020