

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Mar-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 29-Mar-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Mar-20	0:00:00	29-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 30.03.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	29-Mar-20	0:00:00	29-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	29-Mar-20	0:00:00	29-Mar-20	24:00:00	24:00:00	40.00	0.935	
4	29-Mar-20	0:00:00	29-Mar-20	24:00:00	24:00:00	42.00	0.954	
5	29-Mar-20	20:35:00	29-Mar-20	24:00:00	3:25:00	40.00	0.130	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Mar-20	0:00:00	29-Mar-20	0:00:00	0:00:00	0	0.000	Today(i.e. 30.03.2020), 1 SSP-RBPH M/cs are running at 10:00 hrs.
2	29-Mar-20	6:15:00	29-Mar-20	8:45:00	2:30:00	182	0.460	
3	29-Mar-20	6:00:00	29-Mar-20	9:00:00	3:00:00	185	0.550	
4	29-Mar-20	0:00:00	29-Mar-20	0:00:00	0:00:00	0	0.000	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
5	29-Mar-20	0:00:00	29-Mar-20	0:00:00	0:00:00	0	0.000	
6	29-Mar-20	5:45 16:00	29-Mar-20	11:45 19:00	9:00:00	185	1.652	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		2.019	2.662	4.681
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		84.053	131.700	215.753
PREVIOUS DAY ACTUAL RUNNING HOURS		51:25:00	14:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	14:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Mar-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.05 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5283 Cusec 13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15914 Cusec 39 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12381	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	11463	11538	4376	475



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.2: 19:35 hrs on 29.03.2020 to 5:25 hrs on 30.03.2020.