

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
 (ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 31-Mar-20

ISSUE TIME: 10:00 Hrs

FOR DATE: 30-Mar-20

 Daily Plant Report  
 (00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Mar-20	0:00:00	30-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 31.03.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	30-Mar-20	0:00:00	30-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	30-Mar-20	0:00:00	30-Mar-20	20:45:00	20:45:00	40.00	0.806	
4	30-Mar-20	0:00:00	30-Mar-20	24:00:00	24:00:00	41.00	0.958	
5	30-Mar-20	17:30:00	30-Mar-20	24:00:00	6:30:00	39.00	0.248	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Mar-20	6:00:00	30-Mar-20	9:30:00	3:30:00	185	0.650	Today(i.e. 31.03.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	30-Mar-20	0:00:00	30-Mar-20	0:00:00	0:00:00	0	0.000	
3	30-Mar-20	5:30:00	30-Mar-20	9:45:00	4:15:00	185	0.784	
4	30-Mar-20	16:00:00	30-Mar-20	18:45:00	2:45:00	184	0.518	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
5	30-Mar-20	0:00:00	30-Mar-20	0:00:00	0:00:00	0	0.000	
6	30-Mar-20	5:45:00	30-Mar-20	10:00:00	4:15:00	185	0.788	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.012	2.740	4.752
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	86.065	134.440	220.505
PREVIOUS DAY ACTUAL RUNNING HOURS	51:15:00	14:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Mar-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 122.01 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11178 Cusec 27 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13667 Cusec 33 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
11463	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	10864	11447	2220	473



Copy to :

 AEE (EMC)  
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&amp;M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.2:18:50 hrs on 30.03.2020 to 5:50 hrs on 31.03.2020.

Unit No.3:19:50 hrs on 30.03.2020 to 5:55 hrs on 31.03.2020.