



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 05.03.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. CHPH Unit No. 2 is under L/C from 01.03.2020
2	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	4-Mar-20	0:00:12:00:00 17:00:00	4-Mar-20	10:30:15:30:24:00	21:00:00	43.00	0.886	
4	4-Mar-20	0:00:00	4-Mar-20	24:00:00	24:00:00	44.00	1.037	
5	4-Mar-20	0:00:00	4-Mar-20	24:00:00	24:00:00	44.00	1.014	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0	0.000	Today(i.e. 05.03.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0	0.000	
3	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0	0.000	
4	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0	0.000	
5	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0	0.000	
6	4-Mar-20	0:00:00	4-Mar-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.937	0.000	2.937
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	12.703	3.400	16.103
PREVIOUS DAY ACTUAL RUNNING HOURS	69:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	27:30:00	

SSP hydrological data : at 08:00 Hrs on 5-Mar-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.14 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 26877 Cusec 66 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15252 Cusec 37 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14814	605

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
520	0	15174	15252	0	517



[Signature]
AEE (EMC)
NCA, INDORE
5/3/2020

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
 - GoMP. Member(Power),NVDA,Bhopal
 - GoMah. CE,WRD, Mumbai
 - GoG CE(E&M),SSNNL,Vadoadra
- NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Dhule-I, Raj-1 and Raj-2 lines are in service.
2. SCO Mode Running Detail:
Unit No.5: 21:45 hrs on 04.03.2020 to 05:20 hrs on 05.03.2020.
Unit No.6: 22:00 hrs on 04.03.2020 to 05:25 hrs on 05.03.2020.