



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Mar-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Mar-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 06.03.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. CHPH Unit No. 2 is under L/C from 01.03.2020
2	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	5-Mar-20	00:00 19:45	5-Mar-20	18:30 24:00	22:45:00	44.00	0.950	
4	5-Mar-20	0:00:00	5-Mar-20	24:00:00	24:00:00	440.00	1.041	
5	5-Mar-20	0:00:00	5-Mar-20	24:00:00	24:00:00	44.00	1.005	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0	0.000	Today(i.e. 06.03.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 is under AOH from 06.03.2020
2	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0	0.000	
3	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0	0.000	
4	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0	0.000	
5	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0	0.000	
6	5-Mar-20	0:00:00	5-Mar-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.996	0.000	2.996
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	15.699	3.400	19.099
PREVIOUS DAY ACTUAL RUNNING HOURS	70:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	27:30:00	

SSP hydrological data : at 08:00 Hrs on 6-Mar-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.16 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17594 Cusec 43 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15594 Cusec 38 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15174	520

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
514	0	15686	15594	0	519



जल संचयन - जल सौरभ

AEE (EMC)
NCA, INDORE

Handwritten signature and date: 6/3/2020

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Dhule-I, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 20:10 hrs on 05.03.2020 to 06:15 hrs on 06.03.2020.

Unit No.6: 20:20 hrs on 05.03.2020 to 06:25 hrs on 06.03.2020.