



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 07.03.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. CHPH Unit No. 2 is under L/C from 01.03.2020
2	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	6-Mar-20	0:00:00	6-Mar-20	24:00:00	24:00:00	44.00	1.030	
4	6-Mar-20	0:00:00	6-Mar-20	24:00:00	24:00:00	45.00	1.053	
5	6-Mar-20	0:00:00	6-Mar-20	24:00:00	24:00:00	43.00	1.015	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0	0.000	Today(i.e. 07.03.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 is under AOH from 06.03.2020
2	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0	0.000	
3	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0	0.000	
4	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0	0.000	
5	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0	0.000	
6	6-Mar-20	0:00:00	6-Mar-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.098	0.000	3.098
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.797	3.400	22.197
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	27:30:00	

SSP hydrological data : at 08:00 Hrs on 7-Mar-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 124.14 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15001 Cusec 37 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15963 Cusec 39 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15685	514

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
596	0	15426	15963	0	519



Asim
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.4: 22:00 hrs on 06.03.2020 to 06:40 hrs on 07.03.2020.

Unit No.6: 21:10 hrs on 06.03.2020 to 06:35 hrs on 07.03.2020.