



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Mar-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Mar-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 08.03.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. CHPH Unit No. 2 is under L/C from 01.03.2020
2	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	7-Mar-20	0:00:00	7-Mar-20	24:00:00	24:00:00	44.00	1.025	
4	7-Mar-20	0:00:00	7-Mar-20	24:00:00	24:00:00	44.00	1.055	
5	7-Mar-20	0:00:00	7-Mar-20	24:00:00	24:00:00	44.00	1.021	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0	0.000	Today(i.e. 08.03.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 is under AOH from 06.03.2020
2	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0	0.000	
3	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0	0.000	
4	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0	0.000	
5	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0	0.000	
6	7-Mar-20	0:00:00	7-Mar-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.101	0.000	3.101
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	21.898	3.400	25.298
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	72:00:00	61:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	60:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Mar-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.04 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11337 Cusec 28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18224 Cusec 45 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15426	596

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
590	0	15372	15985	2239	517



for Authority 07/03/20

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.3: 20:35 hrs on 07.03.2020 to 05:40 hrs on 08.03.2020.

Unit No.6: 20:40 hrs on 07.03.2020 to 05:45 hrs on 08.03.2020.

AEE (EMC)
NCA, INDORE