



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Mar-20	0:00:00	8-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 09.03.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 2 is under L/C from 01.03.2020. SSP CHPH Unit No. 1 is under L/C from 08.03.2020.
2	8-Mar-20	0:00:00	8-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	8-Mar-20	0:00:00	8-Mar-20	24:00:00	24:00:00	43.00	1.023	
4	8-Mar-20	0:00:00	8-Mar-20	24:00:00	24:00:00	44.00	1.054	
5	8-Mar-20	0:00:00	8-Mar-20	24:00:00	24:00:00	45.00	1.022	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Mar-20	6:00:00	8-Mar-20	19:30:00	13:30:00	198	2.616	Today(i.e. 09.03.2020), 5 SSP-RBPH M/cs are running at 10:00 hrs.  SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
2	8-Mar-20	6:15:00	8-Mar-20	19:45:00	13:30:00	197	2.634	
3	8-Mar-20	6:45 14:45	8-Mar-20	11:45 20:00	10:15:00	198	2.000	
4	8-Mar-20	6:30 15:00	8-Mar-20	11:30 20:15	10:15:00	197	2.020	
5	8-Mar-20	0:00:00	8-Mar-20	0:00:00	0:00:00	0	0.000	
6	8-Mar-20	7:00:00	8-Mar-20	20:30:00	13:30:00	198	2.652	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.099	11.922	15.021
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	24.997	15.322	40.319
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	61:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	49:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	48:30:00	

SSP hydrological data : at 08:00 Hrs on 9-Mar-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 123.74 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13152 Cusec 32 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 34854 Cusec 85 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15372	590

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
595	0	15372	15981	18873	513



AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.3: 21:25 hrs on 08.03.2020 to 05:40 hrs on 09.03.2020.

Unit No.6: 21:35 hrs on 08.03.2020 to 05:35 hrs on 09.03.2020.