



वर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Mar-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 13-Mar-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	13-Mar-21	0:00:00	13-Mar-21	24:00:00	24:00:00	51.00	1.200	Today (i.e. 14.03.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	13-Mar-21	0:00:00	13-Mar-21	24:00:00	24:00:00	50.00	1.206	
3	13-Mar-21	0:00:00	13-Mar-21	24:00:00	24:00:00	51.00	1.202	
4	13-Mar-21	0:00:00	13-Mar-21	0:00:00	0:00:00	0.00	0.000	
5	13-Mar-21	0:00:00	13-Mar-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	13-Mar-21	6:00:00	13-Mar-21	9:00:00	3:00:00	201	0.600	Today (i.e. 14.03.2021), 4 SSP-RBPH M/cs are running at 10:00 hrs.
2	13-Mar-21	6:15 14:30	13-Mar-21	9:15 17:30	6:00:00	200	1.202	
3	13-Mar-21	6:30:00	13-Mar-21	9:30:00	3:00:00	201	0.604	
4	13-Mar-21	6:45:00	13-Mar-21	9:45:00	3:00:00	199	0.600	
5	13-Mar-21	0:00:00	13-Mar-21	0:00:00	0:00:00	0	0.000	SSP RBPH Unit No. 5 is under A.O.H. from 03.03.2021.
6	13-Mar-21	7:00:00	13-Mar-21	10:00:00	3:00:00	198	0.598	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.608	3.604	7.212
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	53.907	48.460	102.367
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	18:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	84:30:00	20:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	20:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Mar-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.94 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7590 Cusec 18.57 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21951 Cusec 53.70 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
16718	618

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
617	0	16655	16477	5474	638



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-
Nil

EE (EMC)
NCA, INDORE

Handwritten signature and date:
J. E. (E. Govt)
Emc, NCA
14/03/21