

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-Mar-21	0:00:00	21-Mar-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 22.03.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	21-Mar-21	0:00:00	21-Mar-21	24:00:00	24:00:00	49.00	1.177	
3	21-Mar-21	0:00:00	21-Mar-21	0:00:00	0:00:00	0.00	0.000	
4	21-Mar-21	0:00:00	21-Mar-21	24:00:00	24:00:00	50.00	1.194	
5	21-Mar-21	0:00:00	21-Mar-21	24:00:00	24:00:00	50.00	1.177	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-Mar-21	6:30:00	21-Mar-21	9:30:00	3:00:00	200	0.604	Today (i.e. 22.03.2021), 4 SSP-RBPH M/cs are running at 10:00 hrs.  SSP RBPH Unit No. 5 is under A.O.H. from 03.03.2021.
2	21-Mar-21	6:45:00	21-Mar-21	9:45:00	3:00:00	198	0.596	
3	21-Mar-21	7:00:00	21-Mar-21	10:00:00	3:00:00	200	0.598	
4	21-Mar-21	14:45:00	21-Mar-21	17:15:00	2:30:00	197	0.498	
5	21-Mar-21	0:00:00	21-Mar-21	0:00:00	0:00:00	0	0.000	
6	21-Mar-21	7:15:00	21-Mar-21	10:30:00	3:15:00	200	0.654	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.548	2.950	6.498
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	84.532	79.956	164.488
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	14:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	16:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	15:00:00	

SSP hydrological data : at 08:00 Hrs on 22-Mar-21

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 127.40 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10499 Cusec 25.69 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21150 Cusec 51.75 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15716	603

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
630	0	17735	16348	4802	597



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 21:10 Hrs on 21.03.2021 to 05:35 Hrs on 22.03.2021.

Unit No.2: 21:00 Hrs on 21.03.2021 to 05:40 Hrs on 22.03.2021.

EE (EMC)  
NCA, INDORE