

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Mar-21	0:00:00	22-Mar-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 23.03.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	22-Mar-21	0:00:00	22-Mar-21	24:00:00	24:00:00	49.00	1.178	
3	22-Mar-21	0:00:00	22-Mar-21	0:00:00	0:00:00	0.00	0.000	
4	22-Mar-21	0:00:00	22-Mar-21	24:00:00	24:00:00	50.00	1.190	
5	22-Mar-21	0:00:00	22-Mar-21	24:00:00	24:00:00	49.00	1.174	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Mar-21	07:00 14:30	22-Mar-21	10:15 17:30	6:15:00	201	1.244	Today (i.e. 23.03.2021), No SSP-RBPH M/c is running at 10:00 hrs. SSP RBPH Unit No. 5 is under A.O.H. from 03.03.2021.
2	22-Mar-21	6:45:00	22-Mar-21	10:00:00	3:15:00	198	0.646	
3	22-Mar-21	6:30:00	22-Mar-21	9:45:00	3:15:00	201	0.652	
4	22-Mar-21	0:00:00	22-Mar-21	0:00:00	0:00:00	0	0.000	
5	22-Mar-21	0:00:00	22-Mar-21	0:00:00	0:00:00	0	0.000	
6	22-Mar-21	6:15:00	22-Mar-21	9:30:00	3:15:00	201	0.654	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.542	3.196	6.738
CUMMULATIVE GROSS GEN. FOR MONTH (Mus)	88.074	83.152	171.226
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	16:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	15:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	19:15:00	

SSP hydrological data : at 08:00 Hrs on 23-Mar-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.21 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4429 Cusec 10.84 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21646 Cusec 52.96 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17734	630

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
600	0	17743	16322	5324	593



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasar, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:- Nil

EE (EMC)
NCA, INDORE