



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Mar-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 06-Mar-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Mar-21	0:00:00	6-Mar-21	24:00:00	24:00:00	50.00	1.185	Today (i.e. 07.03.2021), 4 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 3 is under L/C from 05.03.2021.
2	6-Mar-21	0:00:00	6-Mar-21	24:00:00	24:00:00	51.00	1.198	
3	6-Mar-21	0:00:00	6-Mar-21	0:00:00	0:00:00	0.00	0.000	
4	6-Mar-21	0:00:00	6-Mar-21	24:00:00	24:00:00	51.00	1.203	
5	6-Mar-21	00:00 8:00	6-Mar-21	1:00 24:00	17:00:00	50.00	0.836	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Mar-21	6:15:00	6-Mar-21	10:00:00	3:45:00	200	0.744	Today (i.e. 07.03.2021), 3 SSP-RBPH M/cs are running at 10:00 hrs.  SSP RBPH Unit No. 5 is under A.O.H. from 03.03.2021.
2	6-Mar-21	6:30:00	6-Mar-21	10:15:00	3:45:00	199	0.740	
3	6-Mar-21	6:45:00	6-Mar-21	10:30:00	3:45:00	199	0.744	
4	6-Mar-21	7:00:00	6-Mar-21	10:45:00	3:45:00	200	0.738	
5	6-Mar-21	0:00:00	6-Mar-21	0:00:00	0:00:00	0	0.000	
6	6-Mar-21	7:15:00	6-Mar-21	12:00:00	4:45:00	200	0.948	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.422	3.914	8.336
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	25.773	22.184	47.957
PREVIOUS DAY ACTUAL RUNNING HOURS	89:00:00	19:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	87:00:00	18:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	18:45:00	

SSP hydrological data : at 08:00 Hrs on 7-Mar-21

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 130.00 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8717 Cusec 21.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 25861 Cusec 63.27 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19996	671

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
616	0	19824	19372	6489	666



EE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 3: 18:40 hrs on 06.03.2021 to 05:30 hrs on 07.03.2021.

Unit No. 6: 18:50 hrs on 06.03.2021 to 05:35 hrs on 07.03.2021.

*Handwritten signature and date:*  
I.E. (Elect)  
Emc, NCB.  
07/03/2021