



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Mar-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Mar-21

(CHPH 5X50 MW)								
Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Mar-21	00:00 17:15	7-Mar-21	16:43 24:00	23:28:00	51.00	1.180	Today (i.e. 08.03.2021), 3 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 3 is under L/C from 05.03.2021.
2	7-Mar-21	00:00 17:25	7-Mar-21	16:43 24:00	23:18:00	51.00	1.165	
3	7-Mar-21	0:00:00	7-Mar-21	0:00:00	0:00:00	0.00	0.000	
4	7-Mar-21	9:00 17:00	7-Mar-21	16:43 24:00	14:43:00	50.00	0.732	
5	7-Mar-21	00:00 16:55	7-Mar-21	16:43 24:00	23:48:00	51.00	1.178	

(RBPH 6X200 MW)								
Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Mar-21	6:00:00	7-Mar-21	9:45:00	3:45:00	202	0.750	Today (i.e. 08.03.2021), 3 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit No. 5 is under A.O.H. from 03.03.2021.
2	7-Mar-21	6:15:00	7-Mar-21	10:00:00	3:45:00	196	0.744	
3	7-Mar-21	6:30:00	7-Mar-21	10:15:00	3:45:00	199	0.748	
4	7-Mar-21	6:45:00	7-Mar-21	10:30:00	3:45:00	198	0.754	
5	7-Mar-21	0:00:00	7-Mar-21	0:00:00	0:00:00	0	0.000	
6	7-Mar-21	7:00:00	7-Mar-21	10:45:00	3:45:00	200	0.754	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.255	3.750	8.005
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	30.028	25.934	55.962
PREVIOUS DAY ACTUAL RUNNING HOURS	85:17:00	18:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	85:00:00	18:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	20:45:00	

SSP hydrological data : at 08:00 Hrs on 8-Mar-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 129.82 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8591 Cusec 21.02 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24802 Cusec 60.68 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19512	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
615	0	19025	18970	5832	661



जल संचयन - ऊपर से नीचे

(Signature)
8/3/21
EE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 1: 18:05 hrs on 07.03.2021 to 05:15 hrs on 08.03.2021.

Unit No. 6: 18:20 hrs on 07.03.2021 to 05:20 hrs on 08.03.2021.