


 नर्मदा नियंत्रण प्राधिकरण  
 NARMADA CONTROL AUTHORITY  
**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
 (ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-May-18  
 ISSUE TIME: 10:00 Hrs  
 FOR DATE: 23-May-18

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0.00	0.000 ✓	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0.00	0.000 ✓	
3	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0.00	0.000 ✓	
4	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0.00	0.000 ✓	
5	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0.00	0.000 ✓	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0	0.000 ✓	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0	0.000 ✓	
3	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0	0.000 ✓	
4	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0	0.000 ✓	
5	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0	0.000 ✓	
6	23-May-18	0:00:00	23-May-18	0:00:00	0:00:00	0	0.000 ✓	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.000	0.000	0.000 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	0.000	0.000	0.000 ✓
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00 ✓	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00 ✓	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 24-May-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 105.21 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4912 Cusec
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2601 Cusec
- GOG WATER REQUIREMENT(Next Day) in Cusec

12 MCM ✓

6 MCM ✓

HR	GODBOLE
1971	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
618	0	1978	0	0	2601



नर्मदा नियंत्रण प्राधिकरण

  
 24/05/18  
 AEE (EMC)  
 NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE :I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
 II) SSP-RBPH,SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.  
 III) IBPT operated for maintaining environmental flow into the downstream.  
 NA- Not Available as communication failure at SSP.