



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-May-18
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-May-18

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0.00	0.000	
3	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0.00	0.000	
4	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0.00	0.000	
5	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0	0.000	
3	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0	0.000	
4	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0	0.000	
5	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0	0.000	
6	3-May-18	0:00:00	3-May-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-May-18

DATA RECEIVED FROM FLQOD CELL

- RESERVOIR LEVEL IN Metres 104.43 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3878 Cusec 9 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2733 Cusec 7 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
1983	637

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
643	0	1988	0	0	2733



સર્દાર સારોવાર નિયંત્રણ

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydro), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.

III) IBPT operated for maintaining environmental flow into the downstream.

NA- Not Available as communication failure at SSP.

AEE (EMC)
NCA, INDORE