



(CHPH 5X50 MW)								
Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0.00	0.000 ✓	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m). ✓
2	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0.00	0.000 ✓	
3	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0.00	0.000 ✓	
4	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0.00	0.000 ✓	
5	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0.00	0.000 ✓	

(RBPH 6X200 MW)								
Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m). ✓
2	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0	0.000	
3	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0	0.000	
4	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0	0.000	
5	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0	0.000	
6	4-May-18	0:00:00	4-May-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.000 ✓	0.000 ✓	0.000 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.000 ✓	0.000 ✓	0.000 ✓
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00 ✓	0:00:00 ✓	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00 ✓	0:00:00 ✓	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00 ✓	0:00:00 ✓	

SSP hydrological data : at 08:00 Hrs on 5-May-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 104.41 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2290 Cusec 6 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2681 Cusec 7 MCM ✓
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1983 ✓	637 ✓

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
607	0*	1980	0	0	2681



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP: Member(Power),NVDA,Bhopal
- GoMah: CE,WRD, Mumbai
- GoG CE(E&M),SSNNI,Vadodra

NOTE : I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.

III) IBPT operated for mantaining environmental flow into the downstream.

NA- Not Available as communication failure at SSP.

for Anur
AEE (EMC)
NCA, INDORE
05/05/18