



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-May-18
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-May-18

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0.00	0.000	
3	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0.00	0.000	
4	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0.00	0.000	
5	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0	0.000	
3	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0	0.000	
4	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0	0.000	
5	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0	0.000	
6	7-May-18	0:00:00	7-May-18	0:00:00	0:00:00	0	0.000	

CHPH (5 X 50MW)

RBPH (6X200 MW)

SSP(CHPH+RBPH)

GROSS GENERATION IN(MUS)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 8-May-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 104.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3405 Cusec 8 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2644 Cusec 6 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1987	624

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
628	0	1997	0	0	2644



जल बचत - जल संयत

Signature
8/5/18
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai