



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 10-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 11.05.2019), 0 CHPH M/c is running at 10:00 hrs. Unit No. 2 is under AOH from 04.05.2019 at 9:00 Hrs..
2	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0.00	0.000	
3	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0.00	0.000	
4	10-May-19	0:00:00	10-May-19	5:00:00	5:00:00	33.00	0.162	
5	10-May-19	11:00:00	10-May-19	24:00:00	13:00:00	36.00	0.416	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 11.05.2019), no SSP-RBPH M/c is scheduled. Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs..
2	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0	0.000	
3	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0	0.000	
4	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0	0.000	
5	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0	0.000	
6	10-May-19	0:00:00	10-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.578	0.000	0.578
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	6.311	0.000	6.311
PREVIOUS DAY ACTUAL RUNNING HOURS	18:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 11-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3108 Cusec 8 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4243 Cusec 10 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3387	622

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
620	0	3710	4243	0	606



for *[Signature]*
11/05/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen, and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 and Raj-1 lines are in service.

2. SCO Mode Running Detail:

AEE (EMC)
NCA, INDORE