



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 17-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 16-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0.00	0.000	Today (i.e. 17.05.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 2 is under AOH from 04.05.2019 at 9:00 Hrs..
2	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0.00	0.000	
3	16-May-19	0:00:00	16-May-19	24:00:00	24:00:00	35.00	0.760	
4	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0.00	0.000	
5	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0.00	0.000	

(RRPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0	0.000	Today (i.e. 17.05.2019), no SSP RRPH M/c is scheduled. Unit No. 1 is under outage from 03.05.2019 at 9:00 Hrs.. Unit No. 2 is under outage from 16.05.2019 at 9:00 Hrs..
2	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0	0.000	
3	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0	0.000	
4	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0	0.000	
5	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0	0.000	
6	16-May-19	0:00:00	16-May-19	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)	RRPH (6X200 MW)	SSP (CHPH+RRPH)
GROSS GENERATION IN (MUS)					0.760	0.000	0.760
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)					11.118	0.000	11.118
PREVIOUS DAY ACTUAL RUNNING HOURS					24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)					24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)					24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 17-May-19

DATA RECEIVED FROM FLOOD CELL

RESERVOIR LEVEL IN Metres	119.51 Mtrs.	
AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	1907 Cusec	5 MCM
AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	4809 Cusec	12 MCM
GOG WATER REQUIREMENT (Next Day) in Cusec		

HR	GODROLE
4121	603

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODROLE	OVER FLOW	HR	CHPH	RRPH	Ev. Loss
620	0	4098	4809	0	607

100 Shambh
17.5.19

Copy to :

NCA - Executive Member/Member (Power)/Member (Civil)/SE(EMC)/MD (Hydromet), NCA, INDORE.

GoMP - Member (Power), NVDA, Bhopal

GoMah - CE, WRD, Mumbai

GoG - CE (E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, and Raj-2 Jines are in service.

2. SCO Mode Running Detail:

Unit No.5: 21:10 hrs on 16.05.2019 to 07:55 hrs on 17.05.2019

Unit No.4: 01:45 hrs on 17.05.2019 to 06:15 hrs on 17.05.2019

AEE (EMC)
NCA, INDORE