

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 18.05.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 2 is under AOH from 04.05.2019 at 9:00 Hrs..
2	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0.00	0.000	
3	17-May-19	0:00:00	17-May-19	24:00:00	24:00:00	34.00	0.767	
4	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0.00	0.000	
5	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 18..05.2019), no SSP-RBPH M/c is scheduled. Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs.. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs..
2	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0	0.000	
3	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0	0.000	
4	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0	0.000	
5	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0	0.000	
6	17-May-19	0:00:00	17-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.767	0.000	0.767
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	11.885	0.000	11.885
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.46 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2543 Cusec 6 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4863 Cusec 12 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
4098	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
623	0	4190	4863	0	606



for Archita Kamnaye
S.E. (E lock)
EMC
18.5.19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoC CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 21:40 hrs on 17.05.2019 to 07:15 hrs on 18.05.2019

Unit No.4: 01:25 hrs on 18.05.2019 to 07:10 hrs on 18.05.2019