

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-May-19	17:50:00	18-May-19	24:00:00	6:10:00	34.00	0.195 ✓	Today(i.e. 19.05.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 2 is under AOH from 04.05.2019 at 9:00 Hrs..
2	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0.00	0.000 ✓	
3	18-May-19	0:00:00	18-May-19	20:30:00	20:30:00	33.00	0.658 ✓	
4	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0.00	0.000 ✓	
5	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0.00	0.000 ✓	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 19.05.2019), no SSP-RBPH M/c is scheduled.  Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs.. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs..
2	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0	0.000	
3	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0	0.000	
4	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0	0.000	
5	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0	0.000	
6	18-May-19	0:00:00	18-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.853 ✓	0.000	0.853 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	12.738 ✓	0.000	12.738 ✓
PREVIOUS DAY ACTUAL RUNNING HOURS	26:40:00 ✓	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00 ✓	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00 ✓	0:00:00	

SSP hydrological data : at 08:00 Hrs on 19-May-19

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 119.43 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4273 Cusec ✓ 10 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5424 Cusec ✓ 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4190 ✓	623 ✓

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
620	0	4165	5424	0	605



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, and Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.5: 20:30 hrs on 18.05.2019 to 07:45 hrs on 19.05.2019

Unit No.4: 20:25 hrs on 18.05.2019 to 07:40 hrs on 19.05.2019

*Azeem*  
AEE (EMC)  
NCA, INDORE  
19/05/19