

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-May-19	0:00:00	19-May-19	24:00:00	24:00:00	33.00	0.764	Today(i.e. 20.05.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 2 is under AOH from 04.05.2019 at 9:00 Hrs..
2	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0.00	0.000	
3	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0.00	0.000	
4	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0.00	0.000	
5	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 20.05.2019), no SSP-RBPH M/c is scheduled. Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs.. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs..
2	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0	0.000	
3	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0	0.000	
4	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0	0.000	
5	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0	0.000	
6	19-May-19	0:00:00	19-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.764	0.000	0.764
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	13.502	0.000	13.502
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.43 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5439 Cusec 13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4829 Cusec 12 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4165	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
621	0	4121	4829	0	605



(Signature)
AEE (EMC)
NCA, INDORE
20/5/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, and Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 23:05 hrs on 19.05.2019 to 07:25 hrs on 20.05.2019

Unit No.5: 23:20 hrs on 19.05.2019 to 07:30 hrs on 20.05.2019