



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-May-19	0:00:00	20-May-19	20:00:00	20:00:00	34.00	0.632	Today(i.e. 21.05.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 2 is under AOH from 04.05.2019 at 9:00 Hrs..
2	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0.00	0.000	
3	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0.00	0.000	
4	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0.00	0.000	
5	20-May-19	18:00:00	20-May-19	24:00:00	6:00:00	32.00	0.189	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 21.05.2019), no SSP-RBPH M/c is scheduled. Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs.. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs..
2	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0	0.000	
3	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0	0.000	
4	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0	0.000	
5	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0	0.000	
6	20-May-19	0:00:00	20-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.821	0.000	0.821
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	14.323	0.000	14.323
PREVIOUS DAY ACTUAL RUNNING HOURS	26:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 21-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.47 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8158 Cusec 20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5215 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4121	621

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
627	0	4165	5215	0	606



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, and Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRIDC respectively. The details:

Causing Aho
21/05/19

AEE (EMC)
NCA, INDORE