



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 22-May-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 21-May-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 22.05.2019), 1 CHPH M/c is running at 10:00 hrs.
2	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0.00	0.000	
3	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0.00	0.000	
4	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0.00	0.000	
5	21-May-19	0:00:00	21-May-19	24:00:00	24:00:00	33.00	0.763	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 22.05.2019), no SSP-RBPH M/c is scheduled. Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs.. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs.. Unit No.3 is under outage from 21.05.2019 at 9:30 Hrs..
2	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0	0.000	
3	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0	0.000	
4	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0	0.000	
5	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0	0.000	
6	21-May-19	0:00:00	21-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	0.763	0.000	0.763
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	15.086	0.000	15.086
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 22-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.51 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6180 Cusec 15 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3238 Cusec 8 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4165	627

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
636	0	3561	3238	0	606



जल संचयन - जल संयम

*(Signature)*  
AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WPD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, and Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 20:15 hrs on 21.05.2019 to 07:05 hrs on 22.05.2019

Unit No.5: 20:25 hrs on 21.05.2019 to 07:10 hrs on 22.05.2019