



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 22-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-May-19	8:00:00	22-May-19	15:20:00	7:20:00	33.00	0.235	Today(i.e. 23.05.2019), 1 CHPH M/c is running at 10:00 hrs.
2	22-May-19	15:15:00	22-May-19	24:00:00	8:45:00	32.00	0.277	
3	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0.00	0.000	
4	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0.00	0.000	
5	22-May-19	0:00:00	22-May-19	24:00:00	0:00:00	33.00	0.000	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 23.05.2019), no SSP-RBPB M/c is scheduled. Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs.. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs.. Unit No.3 is under outage from 21.05.2019 at 9:30 Hrs..
2	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0	0.000	
3	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0	0.000	
4	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0	0.000	
5	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0	0.000	
6	22-May-19	0:00:00	22-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.512	0.000	0.512
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	15.598	0.000	15.598
PREVIOUS DAY ACTUAL RUNNING HOURS	16:05:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 23-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.63 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12396 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4786 Cusec 12 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3561	636

AVERAGE QUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
642	0	3693	4786	0	608



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Dhule-2, Raj-2 and Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPB Unit run in Synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:
Unit No.5: 20:25 hrs on 22.05.2019 to 08:10 hrs on 23.05.2019

Arjun
23/05/19
AEE (EMC)
NCA, INDORE