



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 25-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0.00	0.000	Today (i.e. 26.05.2019), 1 CHPH M/c is running at 10:00 hrs.
2	25-May-19	0:00:00	25-May-19	3:00:00	3:00:00	32.00	0.095	
3	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0.00	0.000	
4	25-May-19	8:00:00	25-May-19	24:00:00	16:00:00	35.00	0.543	
5	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0	0.000	Today (i.e. 26.05.2019), no SSP-RBPH M/c is scheduled. Unit No.1 is under outage from 08.05.2019 at 9:00 Hrs.. Unit No.2 is under outage from 16.05.2019 at 9:00 Hrs.. Unit No.3 is under outage from 21.05.2019 at 9:30 Hrs..
2	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0	0.000	
3	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0	0.000	
4	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0	0.000	
5	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0	0.000	
6	25-May-19	0:00:00	25-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.638	0.000	0.638
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	17.767	0.000	17.767
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)*	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 26-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.95 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6816 Cusec 17 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5036 Cusec 12 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
3832	645

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
649	0	3794	5036	0	615

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 KV SSP Asoj, Kasor, Dhule-2, and Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:
Unit No.5: 21:10 hrs on 25.05.2019 to 06:35 hrs on 26.05.2019

for signature
26.05.19
78, NCA.
AEE (EMC)
NCA, INDORE