



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 02-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 03.05.2019), 1 CHPH M/c is running at 10:00 hrs.
2	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0.00	0.000	
3	2-May-19	0:00:00	2-May-19	24:00:00	24:00:00	33.00	0.765	
4	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0.00	0.000	
5	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0.00	0.000	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 03.05.2019), no SSP-RBPB M/c is scheduled.
2	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0	0.000	
3	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0	0.000	
4	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0	0.000	
5	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0	0.000	
6	2-May-19	0:00:00	2-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.765	0.000	0.765
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	1.295	0.000	1.295
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	15:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 3-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5756 Cusec 14 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3407 Cusec 8 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3429	621

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
619	0	3391	3407	0	606

for Report 03/05/19

Conv to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CEWRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1 and Raj-2 lines are in service.

2. SCO MODE DETAILS:

Unit No.2: 20:30hrs on 02.05.2019 to 08:05 hrs on 03.05.2019

Unit No.5: 20:40hrs on 02.05.2019 to 08:10 hrs on 03.05.2019

AEE (EMC)
NCA, INDORE