



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 04-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MU _s	REMARKS
1	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 05.05.2019), 1 CHPH M/c is running at 10:00 hrs.
2	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0.00	0.000	
3	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0.00	0.000	
4	4-May-19	0:00:00	4-May-19	24:00:00	24:00:00	33.00	0.776	
5	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MU _s	REMARKS
1	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 05.05.2019), no SSP RBPH M/c is scheduled.
2	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0	0.000	
3	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0	0.000	
4	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0	0.000	
5	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0	0.000	
6	4-May-19	0:00:00	4-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MU _s)	0.776	0.000	0.776
CUMMULATIVE GROSS GEN. FOR MONTH (MU _s)	2.563	0.000	2.563
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.54 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5015 Cusec 12 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3250 Cusec 8 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
3408	619

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
625	0	3372	3250	0	607

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSSNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 04:10hrs on 05.05.2019 to 08:20 hrs on 05.05.2019

Unit No.5: 04:20hrs on 05.05.2019 to 10:05 hrs on 05.05.2019



for
Arochita Kawaraga
J.E. (Elect) & Inc
5-5-19
NCA

SEE (EMC)
NCA, INDORE