



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-May-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-May-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 06.05.2019), 1 CHPH M/c is running at 10:00 hrs.
2	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0.00	0.000	
3	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0.00	0.000	
4	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0.00	0.000	
5	5-May-19	8:00:00	5-May-19	24:00:00	16:00:00	32.00	0.499	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0	0.000	Today(i.e. 06.05.2019), no SSP-RBPB M/c is scheduled.
2	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0	0.000	
3	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0	0.000	
4	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0	0.000	
5	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0	0.000	
6	5-May-19	0:00:00	5-May-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.499	0.000	0.499
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	3.062	0.000	3.062
PREVIOUS DAY ACTUAL RUNNING HOURS	16:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 6-May-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.58 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7663 Cusec 19 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4704 Cusec 12 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3372	625

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
620	0	3629	4704	0	608



Handwritten signature
AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1 and Raj-2 lines are in service.
2. SCO Mode Running Detail:
Unit No.5: 22:00hrs on 05.05.2019 to 09:20 hrs on 06.05.2019
Unit No.6: 21:45hrs on 05.05.2019 to 09:25 hrs on 06.05.2019